

Incident id	Year	Qtr	Incident Date	Notified date
2604	2012	1	11/01/2012 12:00	12/01/2012 12:00

Other receiver	Permission given to disturb site	Notifier name	Notifier job title	Notifier requested anonymity	Responded date
	No			0	

Category type	Organisation	Regulatory object	Facility type	Incident type	Actual severity	Potential severity
Dangerous Occurrence	Modec Venture 11 B. V.	MODEC Venture 11	FPSO	Damage to safety-critical equipment	0	0

Summary title	Description	Subtypes	Gas kg	Liquid L
OHS - DSCE - Fuel leak - General Alarm & Muster	<p>During facility preparations for Cyclone disconnect an unscheduled muster and the Emergency Response procedure were activated due to a fuel leak above the boiler whilst the boiler was in operation.</p> <p>The boiler was shutdown, fuel isolated and fire fighting foam applied to the top of the boiler to cover the area of spilled fuel.</p>	Facility Integrity, Muster, Near Miss / High Potential, Spill	0	0

Initial decision	Initial decision date	Initial decision reasons	Initial decision notes
No Further Action with the Information Currently Available	13/01/2012 8:20	Minor spill with potential to ignite. No immediate action required await submission of operator's report for review	

Critical decision issues	Critical decision options	Critical decision recommendations	Critical decision last action date	Critical decision reasons	Critical decision	Finalised

3 day report due date	3 day report received date	Final report due date	Final report received date
14/01/2012 12:00	12/01/2012 12:00	10/02/2012 12:00	29/03/2012 12:00

NOPSEMA investigation outcomes	Closed date	Root causes
Reminder to submit final report sent to Operator 07/03/2012 (A210238).		
2nd reminder to submit sent to operator 27/03/2012. (A213486)	17/07/2013 0:00	ED - EQUIPMENT / PARTS DEFECT - QC, ED - PREVENTIVE MAINTENANCE - PM NI - PM for equip NI
Severity = 3 Moderate		